

COMMUNITY AND ECONOMIC DEVELOPMENT DEPARTMENT BUILDING DIVISION

PO Box 1609, Mammoth Lakes, CA 93546 www.townofmammothlakes.ca.gov/building buildingtech@townofmammothlakes.ca.gov (760) 965-3632

2022 CEC Pipe Insulation Requirements

All domestic hot water piping shall be insulated as specified in Section 609.11 of the CPC. In addition, the following piping conditions shall have a minimum insulation wall thickness of 1 inch or a minimum insulation R-value of 7.7:

- i. The first 5 feet of cold water pipes from the storage tank.
- ii. All hot water piping with a nominal diameter equal to or greater than 3/4 inch and less than 1 inch.
- iii. All hot water piping with a nominal diameter less than 3/4 inch that is
 - a. Associated with a domestic hot water recirculation system,
 - b. From the heating source to the kitchen fixtures,
 - c. From the heating source to a storage tank or between storage tanks, or
 - d. Buried below grade.

Exception 4 to section 150.0(j)2: Piping surrounded with a minimum of 1 inch of wall insulation, 2 inches of crawlspace insulation, or 4 inches of attic insulation shall not be required to have pipe insulation. (2022 CEC 150.0(j))

TABLE 120.3-A PIPE INSULATION THICKNESS

| FLUID OPERATING TEMPERATURE RANGE (°F) | INSULATION CONDUCTIVITY | | | NOMINAL PIPE DIAMETER (in inches) | | | | |
|--|--|------------------------------------|-----------------|---|------------|----------|--------|-----------------|
| | CONDUCTIVITY (in Btu·in/h·ft² · °F) | MEAN RATING TEMPERATURE (°F) | | <1 | 1 to < 1.5 | 1.5 to < | 4 to < | 8 and larger |
| Space heating and Service Water Heating Systems (Steam, Steam Condensate, Refrigerant, Space Heating, Service Hot Water) | | | | Minimum Pipe Insulation Required (Thickness in inches or R-value) | | | | |
| Above 350 | 0.32-0.34 | 250 | Inches | 4.5 | 5.0 | 5.0 | 5.0 | 5.0 |
| | | | <i>R</i> -value | R-37 | R-41 | R-37 | R-27 | R-23 |
| 251–350 | 0.29–0.32 | 200 | Inches | 3.0 | 4.0 | 4.5 | 4.5 | 4.5 |
| | | | <i>R</i> -value | R-24 | R-34 | R-35 | R-26 | R-22 |
| 201–250 | 0.27–0.30 | 150 | Inches | 2.5 | 2.5 | 2.5 | 3.0 | 3.0 |
| | | | <i>R</i> -value | R-21 | R-20 | R-17.5 | R-17 | R-14.5 |
| 141–200 | 0.25–0.29 | 125 | Inches | 1.5 | 1.5 | 2.0 | 2.0 | 2.0 |
| | | | <i>R</i> -value | R-11.5 | R-11 | R-14 | R-11 | R-10 |
| 105–140 | 0.22-0.28 | 100 | Inches | 1.0 | 1.5 | 1.5 | 1.5 | 1.5 |
| | | | <i>R</i> -value | R-7.7 | R-12.5 | R-11 | R-9 | R-8 |

007 04/25